



CITY OF SAN ANTONIO

P.O. Box 839966
San Antonio, Texas 78283-3966

ADDENDUM II

SUBJECT: Formal Invitation for Bid, 10-014 Modernization of Passenger Elevators at Central Library, scheduled to open November 13, 2009; date of issue October 15, 2009.

FROM: Paul J. Calapa, Purchasing & Contracts Administrator


DATE: November 4, 2009

ANSWERS TO QUESTIONS RECEIVED AT PRE-BID CONFERENCE ON OCTOBER 22, 2009 AS FOLLOWS:

- Q1 Please confirm existing elevators meet current fire codes, specifically level 1 and level 2?
A1: The City believes existing elevators meet fire codes; no Fire Service code violations have been reported through the State required annual inspection system.
- Q2: The current elevators have Mac equipment; the bid reads "Provide new GAL type compatible to the new door components.", may a Vendor offer Mac compatible components as an alternative?
A2. No, the City is requesting respondents to provide pricing and products as described in the bid.
- Q3: Please clarify the meaning of "dual type switch". Does this mean both key and toggled are required?
A3: Dual means a switch that has a "High", a "Low", and an "Off" setting.
- Q4: Please clarify if door operators and door opening protection should include door tracks, and closers?
A4: The specification does not require tracks and closers to be replaced.
- Q5: Is special key access control pad or panel on the outside of elevator (where the UP and Down buttons are located) to override the security controls required?
A5: The cutout switches are to be located on the inside of the service panel. These will be behind the service cabinet locked door and will be labeled and toggled. An access control pad or panel on the outside of the elevator to override the security controls is not required.
- Q6: Please confirm if uniforms with company logo or nameplates are acceptable.
A6: Uniform, barricades or any work related equipment with company logo are acceptable. There is to be no company name recognition exposed to the public on the new fixtures.

- Q7: Please provide the City's Elevator Consultant name and contact information.
A7: This information will be provided by the City to the successful respondent after an award is made.
- Q8: Please provide engineers estimate and design plans/specs for this project.
A8: The specifications are included as part of the bid document. Engineers estimate and design plans are not available.

****THIS ADDENDUM MUST BE SIGNED AND RETURNED WITH THE BID PACKAGE****



Paul J. Calapa,
Purchasing & Contracts Administrator
Purchasing & General Services Department

Date _____

Company Name _____

Address _____

City/State/Zip Code _____

Signature _____

Print Name/Title _____